



NOTES:

1. OUTER BOX SIZE SHALL BE A MINIMUM OF 30"W X 36"H X 10"D OR AS APPROVED BY PBU.
2. FOR STATIONS WITH PUMPS RATED 20 HP OR GREATER, OUTER BOX SIZE SHALL BE 30"W X 42"H X 10"D OR AS APPROVED BY PBU.
3. DRAWINGS SHALL BE REVISED FOR STATIONS WITH PUMPS RATED GREATER THAN 47 HP AND SUBMITTED TO PBUC FOR APPROVAL.
4. 3/8" S.S. BOLTS AND SPRING NUTS FOR MOUNTING BRACKETS TO BE S.S. UNISTRUTS SIZED PROPERLY

CITY OF PALM BAY, UTILITIES DEPARTMENT
POLICIES, PROCEDURES AND STANDARDS
INSTALLATION DETAIL

DUPLEX CONTROL PANEL ENCLOSURE
DEAD FRONT LAYOUT

DWN.BY: M.K.L.
REV.

DATE: 1-1-08
DWG. NO.

LS-7