



NOTES:

1. FIRE HYDRANT SHALL BE SUPPLIED WITHOUT A WEEP HOLE, OR WITH A PERMANENTLY PLUGGED WEEP HOLE.
2. THE BUILDER MAY INSTALL THE SHEAR PAD RECESSED UP TO 4 INCHES BELOW FINISHED GRADE AND SOD THE RECESSED SECTION.
3. CLEARANCE BETWEEN BOTTOM OF BOLTS AND TOP OF SHEAR PAD SHALL BE A 6" MINIMUM.
4. IF THE HYDRANT IS LOCATED IN THE BOTTOM OF A ROADSIDE SWALE, MOVE THE HYDRANT TO BACKSLOPE OF THE SWALE.
5. CLEARANCE OF SEVEN AND ONE HALF FEET IN FRONT OF AND TO THE SIDES OF FIRE HYDRANTS AND APPLIANCES SHALL BE MAINTAINED. CLEARANCE OF FOUR FEET TO THE REAR OF FIRE HYDRANTS SHALL BE MAINTAINED.
6. FIRE HYDRANTS IN RESIDENTIAL SUBDIVISION/DEVELOPMENTS SHALL BE INSTALLED, WITH INTERMEDIATE HYDRANTS SPACED AT INTERVALS NOT TO EXCEED 1,000 FEET APART. FIRE HYDRANTS SHALL BE LOCATED NOT FURTHER THAN 15 FEET NOR LESS THAN 3 FEET FROM AN IMPROVED SURFACE. City Ord. Sec. 33.28. THE MINUMIM MEASUREMENT STARTS FROM THE OUTSIDE EDGE OF THE CURB.