



NOTES:

1. SAMPLING STATION SHALL BE MODEL #88WC ECLIPSE MANUFACTURED BY THE KUPFERLE FOUNDRY COMPANY
2. BOTTOM OF HOUSING SHALL BE FLUSH WITH THE BOTTOM OF THE CONCRETE PAD
3. HOUSING SHALL BE POSITIONED WITH THE DOOR SIDE CLOSEST TO THE RIGHT OF WAY LINE, SO THAT THE BLOW OFF FACES THE SWALE

CITY OF PALM BAY, UTILITIES DEPARTMENT
POLICIES, PROCEDURES AND STANDARDS
INSTALLATION DETAIL

**WATER MAIN SAMPLING
STATION DETAIL**

DWN.BY: E.K.R.	DATE: 06-14-11
REV.	DWG. NO. W-8B