



1. CLEARANCE OF SEVEN AND ONE HALF FEET IN FRONT OF AND TO THE SIDES OF FIRE HYDRANTS AND APPLIANCES SHALL BE MAINTAINED.
CLEARANCE OF FOUR FEET TO THE REAR OF FIRE HYDRANTS SHALL BE MAINTAINED.

CITY OF PALM BAY, UTILITIES DEPARTMENT
POLICIES, PROCEDURES AND STANDARDS
INSTALLATION DETAIL

**PIV GATE VALVE AND
TWIN HOSE CONNECTOR DETAIL**

DWN. BY: M.K.L.	DATE: 1-1-08
REV.	DWG. NO. W-14